



## **PENETRATION & LINEAR GAP SEALS SCHEME SDP13**

***Certificate number: IFCC 1059***

This is a product certificate to certify that

***Rockwool Ltd***

Pencoed  
Bridgend  
CF35 6NY

Telephone no. +44 (0) 1656 862 621

Who manufacture the following system:

**Rockwool Firepro Fire Resistant Silicone Sealant**

have satisfied the requirements of the above scheme. This includes the testing of products to **BS476: Part 20, EN1366-3 and EN1366-4**, the inspection of their Factory Production Control and continuing surveillance audits and testing of samples of products taken from production. The product specification and field of application to achieve up to 4 hours fire resistance are detailed in the schedule referenced below.



Initial registration: 02 August 2013

Re-issued: 01 August 2018

Valid to: 31 July 2023

Issue No. 2



**175**

A handwritten signature in black ink, which appears to read 'Ian Woodhouse'.

**Ian Woodhouse**  
Director of Certification

---

IFC Certification Ltd, 20 Park Street, Princes Risborough, Buckinghamshire. UK, HP27 9AH  
Tel: +44 (0)1844 275500 Fax: +(0)1844 274002 E-mail: [info@ifccertification.com](mailto:info@ifccertification.com) Web: [www.ifccertification.com](http://www.ifccertification.com)  
Registered No: 4777898 England

The certificate and schedule are held in force by regular annual surveillance visits by IFC Certification and the reader or user should contact IFC Certification to validate its status. This certificate remains the property of IFC Certification and must be returned to them on demand.

## ***Certificate number: IFCC 1059***

The production of penetration and linear gap seals are manufactured in accordance with assessment/ test reports referenced within the following table:

<b>Description</b>	<b>Fire Rating</b>	<b>Assessment/ Test Report</b>
Rockwool Firepro Fire Resistant Silicone Sealant	Up to 240 mins	PAR/12482/02 Rev A Appendices A & B: A1 – A2, B1 – B2.

The scope of the certification is limited to the details and parameters contained within these reports and all aspects of the specification and limitations defined therein must be satisfied.

**It is the certificate holder's responsibility to ensure that the latest version/ revision of the above assessment reports are maintained as part of the audited FPC system.**

**Failure to comply with all specifications will invalidate the certification and may jeopardise the fire performance.**