

Certificate of Product Approval

Certificate Number: 022e

Issue: 03

ROCKWOOL LIMITED

Wern Tarw
Percoed
Bridgend
Mid Glamorgan
CF35 6NY
United Kingdom

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) as detailed below:

Products

Roofing Systems
Cladding Roll – Unfaced, Aluminium foil faced and White tissue faced.
Cavity Batts – Unfaced
Rainscreen Duo-slabs – Unfaced and Black tissue faced.
Flexi Batts – Unfaced
Hardrock Dual Density Roofing Boards – Unfaced, White tissue faced and Black tissue faced
DuoRock Roofing Boards – Unfaced, White tissue faced and Black tissue faced
Rockwool Hardrock Dual Density Multi-Fix – Cream glass fibre tissue faced

Standards

SD198 (Appendix B14) / EN 13501-1
Specific requirements relating to Reaction to Fire (RTF) classifications for Materials and Products.

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward

Certification Scheme Manager

12 December 2016

Date of Issue

25 May 2006

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



Appendix to Certificate No: 022e ROCKWOOL LIMITED

Issue: 03

Product Name	Thickness (mm)	Test / Assessment / Classification Standard	Classification Class	LPCB Ref. No.
Cladding Roll - Unfaced	60 - 180	EN 13501-1:2001	A1	022e/01
Cladding Roll – Aluminium foil faced	60 - 180	EN 13501-1:2001	A1	
Cladding Roll – White tissue faced	60 – 180	EN 13501-1:2001	A1	
Cavity Batts – Unfaced	50 – 150	EN 13501-1:2001	A1	022e/02
Rainscreen Duo-slabs – Unfaced	50 –230	EN 13501-1: 2007	A1	022e/03
Rainscreen Duo-slabs – Black tissue faced	50 -230	EN 13501-1:2007	A1	
Flexi Batts – Unfaced	50 – 150	EN 13501-1:2001	A1	022e/04
Hardrock Dual Density Roofing Boards - Unfaced	50 – 155	EN 13501-1:2001	A1	022e/05
Hardrock Dual Density Roofing Boards – White tissue faced	50 – 155	EN 13501-1:2001	A1	
Hardrock Dual Density Roofing Boards - Black tissue faced	50 – 155	EN 13501-1:2001	A1	
DuoRock Roofing Boards – Unfaced	50 – 180	EN 13501-1:2001	A1	022e/06
DuoRock Roofing Boards – White tissue faced	50 – 180	EN 13501-1:2001	A1	
DuoRock Roofing Boards – Black tissue faced	50 – 180	EN 13501-1:2001	A1	
Rockwool Hardrock Dual Density Multi-Fix – Cream glass fibre tissue faced	50 - 185	EN 13501-1:2007 + A1:2009	A1	022e/07

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Damien Ward

Signed for LPCB

Damien Ward

Certification Scheme Manager

12 December 2016

Date of Issue

25 May 2006

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)333 321 8811 F: +44 (0)1923 664603 E: enquiries@breglobal.com



bre